

STATE OF NEBRASKA
DEPARTMENT OF ROADS
ADDENDUM NO. 1
PROJECT NO. STPD-23-3(105)
CONTROL NO. 70725
CALL ORDER 700
N-23, LOOMIS - HOLDREGE
LETTING DATE: JULY 9, 2009

On page 141 of the Special Provisions, in the provision titled **HYDRATED LIME SLURRY FOR ASPHALT MIXTURES**, the first paragraph is void and superseded by the following:

2. **Material Requirements** – The lime shall meet the chemical and physical properties defined in AASHTO M 303 for Type I – High calcium-hydrated lime, or meet the requirements of ASTM 1097 for Type S Hydrated Lime.

DEPARTMENT OF ROADS

Original Signed by Liz Wunderlich

For Claude Oie
Construction Engineer

Issued: June 30, 2009

CO:KM:700AD107

NOTICE: Only the contractors issued bidding proposals receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the contractor.